

ORIGINAL



0000163690



RECEIVED  
AZ CORPORATION COM  
DOCKET CONTROL

2015 JUL 17 AM 10 20

15996 Ironwood Drive,  
P.O. Box 38  
Dolan Springs, AZ 86441  
928-767-3713 Fax: 928-767-3053

Arizona Corporation Commission

**DOCKETED**

**JUL 17 2015**

DOCKETED BY

MLB

July 14, 2015

Docket Control Center  
Arizona Corporation Commission  
1200 W. Washington St.  
Phoenix, AZ 85007

Re: Docket No. W-02105A-09-0522, Decision No. 72001

Here is our revised water report for the second quarter of 2015. The reason for this revision is I noticed that issues that arose with each quarter were not listed on the water loss spread sheet.

We have started a meter change-out program to remove old meters and replace with new meters to control and help to lower water loss. 150 new meters were purchased to account for changing out approx. 20% of all residential meters we have in ground. We experienced more repairs during the 2<sup>nd</sup> quarter.

The company is in process of conducting a detailed water audit of the year 2014-2015 to come up with a detailed water loss plan going forward for the next 5 years. A separate letter will be sent asking for additional time to complete this detailed plan.

Please let me know if you have any questions.

Regards,

Joseph Duarte  
Office Mgr.

# **Mt. Tipton Water Company Water Pumped and Sold**

**Calendar Year 2015**

**Docket No. W-20105A-09-0522 and Decision No. 72001**

Month	Gal. Pumped	Gal. Sold	Gal. Lost	Loss/MO. %	#of Cust.
January	3,262,500	2,426,713	835,766	25.6%	658
February	2,575,000	1,662,181	909,819	35.3%	657
March	2,736,200	2,273,245	441,705	16.1%	668
<b>1st Qtr Total</b>	<b>8,573,700</b>	<b>6,362,139</b>	<b>2,187,290</b>	<b>25.5% 1st Qtr. Avg.</b>	<b>661</b>
During this quarter we had 3 Blow-offs, a small and medium sized overflow and a major cleaning of our #8 well intake of roots from growth within our naturally occurring spring. 6 meters were replaced during this time.					
April	3,510,800	2,962,966	498,234	14.2%	658
May	2,831,400	2,389,255	415,245	14.7%	663
June	4,372,100	3,505,755	832,245	19.0%	665
<b>2nd Qtr Total</b>	<b>10,714,300</b>	<b>8,857,976</b>	<b>1,745,724</b>	<b>16.3% 2nd Qtr. Avg.</b>	<b>662</b>
During this quarter we had 7 blow-offs due to repairs on lines, 5 overflows due to float failure, 2 line breaks, meter failure at one of our well heads and we replaced 76 old meters.					
July				#DIV/0!	
August				#DIV/0!	
September				#DIV/0!	
<b>3rd Qtr Total</b>	<b>0</b>	<b>0</b>	<b>0</b>		<b>3rd Qtr. Avg.</b>
October				#DIV/0!	
November				#DIV/0!	
December				#DIV/0!	
<b>4th Qtr Total</b>	<b>0</b>	<b>0</b>	<b>0</b>		<b>4th Qtr. Avg.</b>
<b>YearlyTotal =</b>					